



**GOVERNMENT OF TAMIL NADU**  
**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE**

**SANITARY CERTIFICATE**

YEAR 2025-2026

**APPENDIX-3**


(Chapter III Rule:24)  
Tamil Nadu Educational Rules

K.Dis.No:3095/A4/2025 DT: .04.2025

Office of the District  
Health officer, Namakkal.

I hereby declare that I have inspected the The Modern Academy School, N.Pudupatty Village, Mohanur Taluk, Namakkal District Building and premises on the day of 15.04.2025 and certify

- : that the accommodation provided for each of the several Classes is sufficient for the maximum number of pupil taught there in and is properly ventilated and lighted ;
- : that the building is maintained in substantial repair;
- : that is neat and clean;
- : that the latrine arrangements are adequate and satisfactory;
- : that the supply of drinking water is wholesome and
- : that in all other necessary respects the sanitation is satisfactory.
- : this certificate valid upto one year from the date of issue.



Signature : *Don. J. S. S. S.*  
Designation : BLOCK HEALTH SUPERVISOR  
GOVT. PRIMARY HEALTH CENTRE  
PALAPATTY - 637 017  
MOHANUR BLOCK, NAMAKKAL (DI

**PRINCIPAL** District Health Officer,

THE MODERN ACADEMY SCHOOL, N.PUDUPATTI, MOHANUR TALUK, NAMAKKAL - 637 020.

*Don. J. S. S. S.*  
**CORRESPONDENT**  
THE MODERN ACADEMY SCHOOL  
N.PUDUPATTI, MOHANUR TALUK,  
NAMAKKAL - 637 020.





**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD**  
**DISTRICT WATER TESTING LABORATORY**

Room No.304, Collector Office Annexure Building, Namakkal-637002

Phone:04286-294620

Email:districtlabnamakkal@gmail.com



TC - 14820

**TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	2025/4571	Report Issue Date :	13.06.2025
Invoice Details:	6034/Dt -10.06.2025/Amt.Rs.1652/-		
ULR No	TC148202500000136F		

Client Name & Address	:	The Modern Academy, N.Pudupatti, Trichy Road, Namakkal.
Contact No / Email.ID	:	
Sample Name	:	Water
Sample Description	:	Drinking water
Sample Done by	:	Kumaresan
Sampling Location & Date	:	The Modern Academy School & 10.06.2025
Quantity of sample Received	:	2 Litre
Sample Container	:	Jerry Cane – Good condition
Sample Condition on Receipt	:	Good
Sample Received On	:	10.06.2025
Test Commenced on	:	10.06.2025
Test Completed on	:	13.06.2025
Environmental Condition	:	23.0°C - 27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	-	6.55	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	IS 3025 Part 21-2009(RA 2019)	mg/L	16.00	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	IS 3025-Part 23-2023	mg/L	20.00	200	600
4	Chloride as Cl	IS 3025-Part 32-(RA 2019)	mg/L	24.00	250	1000
5	Sulphate as SO <sub>4</sub>	IS 3025(Part 24/Sec 1):2022 (Turbidity Method)	mg/L	<0.5	200	400
6	Nitrate as NO <sub>3</sub>	APHA 24rd Edition – 4500 –NO <sub>3</sub> B:2023	mg/L	<0.2	45	45
7	Fluoride as F	APHA 24rd Edition – 4500 –F- D:2023	mg/L	<0.2	1.0	1.5

Remarks : The tested samples conformed to IS: 10500-2012(RA-2019) Drinking water Acceptable limit specification with respect to above tested parameter.

*M. R. Boban*  
**CORRESPONDENT**  
**THE MODERN ACADEMY SCHOOL**  
**N.PUDUPATTI, MOHANUR TALUK,**  
**NAMAKKAL - 637 020.**

....End of the report.....

*D.Y.*  
**PRINCIPAL**

**THE MODERN ACADEMY SCHOOL**  
**N.PUDUPATTI, MOHANUR TALUK,**  
**NAMAKKAL - 637 020.**

*S.S.*  
 Reviewed and Authorised by Signatory  
 Junior Water Analyst.

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.





**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD**  
**DISTRICT WATER TESTING LABORATORY**

Room No.304, Collector Office Annexure Building, Namakkal-637002

Phone:04286-294620

Email:districtlabnamakkal@gmail.com.

**TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	2025/ 4571	Report Issue Date :	13.06.2025
Invoice Details:	6034/Dt.10.06.2025/Amt.Rs.1652/-		

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
8	Appearance	Physical observation	--	Clear	-	-
9	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
10	Odour	IS 3025 Part 5 : 1983	--	None	-	-
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	69	500	2000
13	Conductivity	APHA 23rd Edition 2017 - 2510 B	μS/cm	99	-	-
14	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
15	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	8	75	200
16	Magnesium as Mn	APHA 23rd Edition 2017- 3500 Mg B	mg/L	0	30	100
17	Sodium as Na	APHA 23rd Edition 2017 - 3500 Na B	mg/L	7	-	-
18	Potassium as K	APHA 23rd Edition 2017 - 3500 K B	mg/L	3	-	-
19	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0.0	0.3	1.0
20	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.0	0.1	0.3
21	Ammonia as NH <sub>3</sub>	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.0	0.5	0.5
22	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017- 4500-NO2 B	mg/L	0.0	-	-
23	Total Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.0	-	-
24	Tidys 4 hr. test	APHA 23rd Edition 2017 - 4500 O - B	mg/L	-	-	-
25	Free residual chlorine mg/L		mg/L	0.0	0.2	1.0
	<b>III. Bacteriological Examination</b>					
26	Faecal Coliform per 100 ml	IS/APHA	CFU	0	0	0

**REPORT :** The given water sample is chemically potable and Bacteriologically not contaminated.

**94.06.2025**  
**CORRESPONDENT**  
**THE MODERN ACADEMY SCHOOL**  
**N.PUDUPATTI, MOHANUR TALUK,**  
**NAMAKKAL - 637 020.**

**PRINCIPAL**  
**THE MODERN ACADEMY SCHOOL**  
**N.PUDUPATTI, MOHANUR TALUK,**  
**NAMAKKAL - 637 020.**

Reviewed and Authorised by Signatory  
Junior Water Analyst.

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.